



TECHNICKÝ A ZKUŠEBNÍ ÚSTAV STAVEBNÍ PRAHA, s.p.
Technical and Test Institute for Construction Prague

Akreditovaná zkušební laboratoř, Autorizovaná osoba, Notifikovaná osoba, Oznamovaný subjekt, Subjekt pro technické posuzování, Certifikační orgán, Inspekční orgán / Accredited Testing Laboratory, Authorized Body, Notified Body, Technical Assessment Body, Certification Body, Inspection Body. Prosecká 811/76a, 190 00 Praha 9 - Prosek, Czech Republic

Branch 0300 – Pilsen

CERTIFICATE

No. 030 – 054520

About the qualities of a product

Certified quality: SLIPPERINESS according to the following test procedures:

- DIN 51130** Testing of floor coverings determination of anti – slip properties; workrooms and fields of activities with raised slip langer, walking method – ramp test
- P CEN/TS 16165** Determination of slip resistance of pedestrian surfaces – Methods of evaluation

Product: Ceramic tiles dry-pressed, EN 14411, Annex G, group BI_a, UGL
type: Bazo Beige Gres Sól – Pieprz 198 x 198 mm STR

Producer: Ceramika Paradyż Sp. z o.o., ul. Ogrodowa 5, 26-300 Opoczno, Poland

Order: Z 030170080

Achieved values and recommended use:

Testing samples	Critical angle of slip classification according DIN 51130, P CEN/TS 16165 (annex B)
Bazo Beige Gres Sól – Pieprz 198 x 198 mm STR	28,4° R12

The certificate is issued on the basis of the results of the tests stated in report no. 030–054519 from 23rd February 2017.

Number of pages of certificate: 1

Certificate validity: till 28th February 2020

The certificate can be cancelled upon finding non-adherence to the certified parameters of product qualities.

Pilsen 23rd February 2017



Ing. Alexander Trinner
Branch Director

Warning: Without a written consent of the representative of the head of the authorised person, this report must not reproduced otherwise than in its entirety.