



Branch 0300 – Pilsen

# CERTIFICATE

No. 030 – 054719

## About the qualities of a product

**Certified quality: SLIPPERINESS** according to the following test procedures:

**DIN 51097** Testing of floor coverings determination of anti – slip properties wet-loaded barefoot areas; walking method – ramp test

**P CEN/TS 16165** Determination of slip resistance of pedestrian surfaces – Methods of evaluation

**Product:** Ceramic tiles dry-pressed, EN 14411, Annex G, group BI<sub>a</sub>, type: INTERO, format 598 x 598 mm

**Producer:** Ceramika Paradyż Sp. z o.o., ul. Piotrkowska 61, 26-300 Opoczno, Poland

**Order:** Z 030170112

**Achieved values and recommended use:**

Testing samples	Critical angle of slip classification according DIN 51097, P CEN/TS 16165 (annex A)
INTERO, format 598 x 598 mm	23° B


The certificate is issued on the basis of the results of the tests stated in report no. 030–054417 from 7<sup>th</sup> April 2017.

Number of pages of certificate: 1

Certificate validity: **till 30<sup>th</sup> April 2020**

The certificate can be cancelled upon finding non-adherence to the certified parameters of product qualities.

Pilsen 7<sup>th</sup> April 2017



**Ing. Alexander Trinner**  
Branch Director

**Warning:** Without a written consent of the representative of the head of the authorised person, this report must not reproduced otherwise than in its entirety.