

Test Report No. <u>2823/19</u> Sassuolo, 21/03/19

CENTRO DI RICERCA E SPERIMENTAZIONE
PER L'INDUSTRIA CERAMICA

Requested by:	CERAMIKA PARADYZ Sp.z.o.o. UI. Piotrkowska, 61 – 26-300 Opoczno - POLAND			
For the sample:	Unglazed ceramic tiles 59,8 x 59,8 x 0,9 cm maked "INTERO GRES REKT. MAT 59,8x59,8 cm".			
On (date): 04/	Date of receipt in laboratory (sample delivered by the client): 26/02/19		6/02/19	
Test date		From: 06/03/19	То: 06	/03/19

## DIN 51097 (11/1992) – Determination of anti – slip properties. Wet-loaded barefoot areas – Walking method – Ramp test

## WORKING CONDITIONS:

Size of the tested surface (m):	0,50 x 1,20
Joint width (mm):	2
Grout:	Cement mortar
Surface orientation:	None

## **RESULTS**

Average slip angle:	23°
Application range:	A+B

Eng. Giordana Carani Technical appl



The results reported relate only to the samples tested. No responsibility is taken for the accuracy of the sampling unless it is done under our own supervision. The reproduction of this test report is only authorized in the form of a complete photographic facsimile. Our written approval is necessary for any partial reproduction. This test report consists of 1 pages, this cover included.

Via Martelli 26 40138 Bologna – Italy Tel. +39 051 534015 Fax +39 051 530085 Part. IVA 0094778-0375 centro.ceramico@centroceramico.it www.centroceramico.it Viale Valle d'Aosta 1 41049 Sassuolo (MO) – Italy Tel. +39 0536 802154 Fax +39 0536 800662