



TECHNICKÝ A ZKUŠEBNÍ ÚSTAV STAVEBNÍ PRAHA, s.p.
Technical and Test Institute for Construction Prague, SOE

Akreditovaná zkušební laboratoř, Autorizovaná osoba, Notifikovaná osoba, Oznamovaný subjekt, Subjekt pro technické posuzování, Certifikační orgán, Inspekční orgán / Accredited Testing Laboratory, Authorized Body, Notified Body, Technical Assessment Body, Certification Body, Inspection Body, Prosecká 811/76a, 190 00 Praha 9 - Prosek, Czech Republic

Branch 0300 – Pilsen

CERTIFICATE

No. 030 – 055862

About the qualities of a product

Certified quality: SLIPPERINESS according to the following test procedures:

DIN 51097 Testing of floor coverings; determination of anti – slip properties wet-loaded barefoot areas; walking method – ramp test

DIN 51130 Testing of floor coverings determination of anti – slip properties; workrooms and fields of activities with raised slip langer, walking method – ramp test

Product: Ceramic tiles dry-pressed, EN 14411, Annex G, group BIa
type: RS--198X198-1- GAMO._GAMMO GRES SZKLIWIONY STRUKTURA 19,8X19,8 G1 (198/198 mm)

Customer: CERAMIKA PARADYŻ SP. ZO.O., Ul. Piotrkowska 61, 26-300 Opoczno, Poland

Producer: CERAMIKA PARADYŻ SP. ZO.O., Ul. Ogrodowa 5, 26-300, Opoczno, Poland

Order: Z030 17 0431

Achieved values:

Testing of samples	DIN 51097 (barefoot) classification	DIN 51130 (shoe) classification
RS--198X198-1- GAMO._GAMMO GRES SZKLIWIONY STRUKTURA 19,8X19,8 G1 (198/198 mm)	23° B	26,2° R 11

The certificate is issued on the basis of the results of the tests stated in report no. 030–055861 from 2017-11-02.

The certificate is extended based on the manufacturer's statement that the production technology is unchanged.

Number of pages of certificate: 1

Certificate validity: **till 30th November 2020**

The certificate can be cancelled upon finding non-adherence to the certified parameters of product qualities.



Ing. Alexander Trinner

Plzeň 2nd November 2017

Stamp of ZÚS – branch Pilsen

Branch Director

Warning: Without a written consent of the representative of the head of the authorised person, this report must not reproduced otherwise than in its entirety.

Technical and testing construction institute Prague, state enterprise, branch 0300 - Pilsen, Zahradní 15, 326 00 Pilsen, Czech Republic
☎: 377 243 331, ☎: 377 430 345, Fax:+420 377 430 347, Internat.:+420 377 244 158, ✉ e-mail: kotorova@tzus.cz, www.tzus.cz
Banking details: KB Prague 1 Czech Republic, account number: 1501-931/0100 Co. Id. No.: 000 15679 Tax Co. Id. No.: CZ-00015679