



**TECHNICKÝ A ZKUŠEBNÍ ÚSTAV STAVEBNÍ PRAHA, s.p.**  
**Technical and Test Institute for Construction Prague, SOE**  
Akreditovaná zkušební laboratoř, Autorizovaná osoba, Notifikovaná osoba, Oznamovaný subjekt, Subjekt pro technické posuzování, Certifikační orgán, Inspekční orgán / Accredited Testing Laboratory, Authorized Body, Notified Body, Technical Assessment Body, Certification Body, Inspection Body. Prosecká 811/76a, 190 00 Praha 9 - Prosek, Czech Republic

Branch 0300 – Pilsen

# CERTIFICATE

No. 030 – 056263

## About the qualities of a product

**Certified quality: SLIPPERINESS** according to the following test procedures:

**DIN 51097** Testing of floor coverings determination of anti – slip properties wet-loaded barefoot areas; walking method – ramp test

**P CEN/TS 16165** Determination of slip resistance of pedestrian surfaces – Methods of evaluation

**Product: Ceramic tiles dry-pressed, EN 14411, Annex G, group BI<sub>a</sub>,**  
type: TERO 60 x 60 cm

**Customer: Ceramika Paradyż Sp. Z O.O., Ul. Piotrkowska 61, 26-300 Opoczno, Poland**

**Producer: Ceramika Paradyż Sp. Z O.O., ZAKŁAD WIELKA WOLA, Wielka Wola 14, 26-333 Paradyż, Poland**

**Order: Z 030180036**

### Achieved values and recommended use:

Testing samples	Critical angle of slip classification according DIN 51097, P CEN/TS 16165 (annex A)
TERO 60 x 60 cm	16° A

The certificate is issued on the basis of the results of the tests stated in report no. 030–056262 from 8<sup>th</sup> February 2018.

Number of pages of certificate: 1

Certificate validity: till 28<sup>th</sup> February 2021

The certificate can be cancelled upon finding non-adherence to the certified parameters of product qualities.

Pilsen 8<sup>th</sup> February 2018



Stamp of TZÚS s. branch Pilsen

Ing. Alexander Trinner  
Branch Director

**Warning:** Without a written consent of the representative of the head of the authorised person, this report must not reproduced otherwise than in its entirety.

Technical and testing construction institute Prague, state enterprise, branch 0300 - Pilsen, Zahradní 15, 326 00 Pilsen, Czech Republic  
☎: 377 243 331, ☎: 377 430 345, Fax: +420 377 430 347, Internat.: +420 377 244 158, ✉ e-mail: [kotorova@tzus.cz](mailto:kotorova@tzus.cz), [www.tzus.cz](http://www.tzus.cz)  
Banking details: KB Prague 1 Czech Republic, account number: 1501-931/0100 Co. Id. No.: 000 15679 Tax Co. Id. No.: CZ-00015679