



Branch 0300 – Pilsen

CERTIFICATE

No. 030 – 056432

About the qualities of a product

Certified quality: SLIPPERINESS according to the following test procedures:

- DIN 51097:1992** Testing of floor coverings determination of anti – slip properties wet-loaded barefoot areas; walking method – ramp test
- P CEN/TS 16165:2013** Determination of slip resistance of pedestrian surfaces – Methods of evaluation

Product: Ceramic tiles dry-pressed, EN 14411, Annex G, group BI_a,
type: TERRACE GRAFIT GRES Szkl. Rekt. 20mm Mat. 59,8 x 59,8 cm G1

Customer: Ceramika Paradyż Sp. Z O.O., Ul. Piotrkowska 61, 26-300 Opoczno, Poland

Producer: Ceramika Paradyż Sp. z o.o., ZAKŁAD WIELKA WOLA, Wielka Wola 14, 26-333 Paradyż, Poland

Order: Z 030180102

Achieved values and recommended use:

Testing samples	Critical angle of slip classification according DIN 51097, P CEN/TS 16165 (annex A)
TERRACE GRAFIT GRES Szkl. Rekt. 20mm Mat. 59,8 x 59,8 cm G1	>24° C

The certificate is issued on the basis of the results of the tests stated in report no. 030–056414 from 26th March 2018.

Number of pages of certificate: 1

Certificate validity:

till 31st March 2021

The certificate can be cancelled upon finding non-adherence to the certified parameters of product qualities.

Pilsen 26th March 2018



Stamp of ZÚS branch Pilsen

Ing. Alexander Trinner
Branch Director

Warning: Without a written consent of the representative of the head of the authorised person, this report must not reproduced otherwise than in its entirety.