

CENTRO DI RICERCA E SPERIMENTAZIONE
PER L'INDUSTRIA CERAMICA

Requested by:	CERAMIKA PARADYZ Sp.z.o.o. Ul. Piotrkowska, 61 26-300 Opoczno - POLAND	
For the sample:	Ceramic tiles 30 x 120 x 2 cm, marked "WILLOW GRES".	
On (date): 11/09/2020	Date of receipt in laboratory (sample delivered by the client):	16/09/2020
Sampling details	By whom: CUSTOMER	
- Where: -----		
- Date: -----		
- How (methods): -----		
Tested in: Sassuolo	Date of starting: 21/09/2020	Date of ending: 21/09/2020

DIN 51097:1992


Determination of anti – slip properties. Wet-loaded barefoot areas – Walking method – Ramp test

OPERATIVE CONDITIONS

Size of the tested surface (m): 0,5x1,0

Fixing scheme

walking direction



RESULTS

Average slip angle: >24°

CLASSIFICATION (DGUV INFORMATION 207-006_JUNI 2015)

Application range: A+B+C

Pietro Bruzzi
Technical verification



Prof.ssa Maria Chiara Bignozzi
Director

-----End of report-----

The results reported relate only to the samples tested. No responsibility is taken for the accuracy of the sampling unless it is done under our own supervision. The reproduction of this test report is only authorized in the form of a complete photographic facsimile. The texts in inverted commas are Customer's declarations and fall under his responsibility. Our written approval is necessary for any partial reproduction. This test report consists of 1 page